

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028


CLIENT: Spring Street Analytical
Project: City of Klamath Falls Lead & Coppers
Lab Order: 1606D40

Date: 19-Jul-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

7/19/2016

Maurene Ehlers
Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

TEL: (541) 882-6286

FAX: (541) 882-9561

RE: City of Klamath Falls Lead & Coppers

Order No.: 1606D40

Dear Maurene Ehlers:

Neilson Research Corporation received 16 sample(s) on 6/29/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-01A
Collection Date: 6/29/2016 7:03:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16738
Collectors Name: Andy Foster
Sample Location: Shasta Room #1
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0109		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00244		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-02A
Collection Date: 6/29/2016 7:05:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16733
Collectors Name: Andy Foster
Sample Location: Shasta Room #13
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0195		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00189		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-03A
Collection Date: 6/29/2016 7:12:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16714
Collectors Name: Andy Foster
Sample Location: Ferguson DF by Office
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.00973		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00358		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-04A
Collection Date: 6/29/2016 7:14:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16741
Collectors Name: Andy Foster
Sample Location: Ferguson Room #25
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0416		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00114		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-05A
Collection Date: 6/29/2016 7:20:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16722
Collectors Name: Andy Foster
Sample Location: Peterson Room #15
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.000884		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.000337		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA QR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-06A
Collection Date: 6/29/2016 7:23:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16715
Collectors Name: Andy Foster
Sample Location: Peterson Room #16
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.00462		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.000368		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-07A
Collection Date: 6/29/2016 7:30:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16719
Collectors Name: Andy Foster
Sample Location: Sterns Room #3
Source: City Water

ANALYTICAL RESULTS

Analyses	-Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.00396		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00142		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-08A
Collection Date: 6/29/2016 7:32:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16740
Collectors Name: Andy Foster
Sample Location: Sterns Room #4
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0185		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00111		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-09A
Collection Date: 6/29/2016 7:38:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16706
Collectors Name: Andy Foster
Sample Location: Mazama DF by Office
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0228		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.000905		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-10A
Collection Date: 6/29/2016 7:41:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16855
Collectors Name: Andy Foster
Sample Location: Mazama DF by Hall 50
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP			MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result					
Copper	EPA 200.8	A	0.0512	0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00592	0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-11A
Collection Date: 6/29/2016 7:53:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16787
Collectors Name: Andy Foster
Sample Location: Brixner Room #19
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0356		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.000580		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-12A
Collection Date: 6/29/2016 7:56:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16704
Collectors Name: Andy Foster
Sample Location: Brixner Music Room
Source: City Water

ANALYTICAL RESULTS

Analyses	NELAP			MRL	Units	EPA Limit	Date Analyzed	Analyst
	Method	Accredited	Result					
Copper	EPA 200.8	A	0.0268	0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.000178	0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-13A
Collection Date: 6/29/2016 8:05:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16807
Collectors Name: Andy Foster
Sample Location: Henley MS DF by Room #19
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.00398		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00466		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100018
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-14A
Collection Date: 6/29/2016 8:07:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16886
Collectors Name: Andy Foster
Sample Location: Henley MS Room #21
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0132		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.0137		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-15A
Collection Date: 6/29/2016 8:14:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16885
Collectors Name: Andy Foster
Sample Location: Henley HS Concession
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0329		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.00647		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Spring Street Analytical
350 Spring Street
Klamath Falls, OR 97601

Lab Order: 1606D40
NRC Sample ID: 1606D40-16A
Collection Date: 6/29/2016 8:15:00 AM
Received Date: 6/29/2016 1:40:00 PM
Reported Date: 7/19/2016 10:21:17 AM

Sample Information:

City of Klamath Falls Lead & Coppers

Client Sample ID: Bottle #16891
Collectors Name: Andy Foster
Sample Location: Henley HS in Gym
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	0.0128		0.000515	mg/L	1.3 AL	7/15/2016	OML
Lead	EPA 200.8	A	0.000457		0.000103	mg/L	0.020 AL	7/15/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

Date: 19-Jul-16

CLIENT: Spring Street Analytical
 Work Order: 1606D40
 Project: City of Klamath Falls Lead & Coppers
ANALYTICAL QC SUMMARY REPORT
 TestCode: ICPMS_200.8_SCHOOL

Sample ID: MB-35691	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: ZZZZZ	Batch ID: 35691	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1324988						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	ND	0.000515									
Lead	ND	0.000103									

Sample ID: MB-35693	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: ZZZZZ	Batch ID: 35693	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325016						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	ND	0.000515									
Lead	ND	0.000103									

Sample ID: LCS-35691	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: ZZZZZ	Batch ID: 35691	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1324989						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	0.09949	0.000520	0.1	0	99.5	85	115				
Lead	0.09739	0.000104	0.1	0	97.4	85	115				

Sample ID: LCS-35693	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: ZZZZZ	Batch ID: 35693	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325017						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	0.09861	0.000520	0.1	0	98.6	85	115				
Lead	0.09585	0.000104	0.1	0	95.8	85	115				

Sample ID: 1606D40-14AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: Bottle #16886	Batch ID: 35691	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325012						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

Neilson Research Corporation

Date: 19-Jul-16

CLIENT: Spring Street Analytical
Work Order: 1606D40
Project: City of Klamath Falls Lead & Coppers

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL


Sample ID: 1606D40-14AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: Bottle #16886	Batch ID: 35691	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325012						
Analyte	Result	MRL	SPK value	SPK RefVal	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Copper	0.1077	0.000520	0.1	0.0132	94.5	70	130				
Lead	0.1084	0.000104	0.1	0.01366	94.7	70	130				

Sample ID: 1606E27-08AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: ZZZZZ	Batch ID: 35693	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325040						
Analyte	Result	MRL	SPK value	SPK RefVal	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Copper	0.3256	0.000520	0.1	0.2176	108	70	130				
Lead	0.1089	0.000104	0.1	0.01433	94.6	70	130				

Sample ID: 1606D40-14AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: Bottle #16886	Batch ID: 35691	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325013						
Analyte	Result	MRL	SPK value	SPK RefVal	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Copper	0.1048	0.000520	0.1	0.0132	91.6	70	130	0.1077	2.74	20	
Lead	0.1068	0.000104	0.1	0.01366	93.2	70	130	0.1084	1.45	20	

Sample ID: 1606E27-08AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/5/2016	RunNo: 88473						
Client ID: ZZZZZ	Batch ID: 35693	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/15/2016	SeqNo: 1325041						
Analyte	Result	MRL	SPK value	SPK RefVal	%REC	LowLimit	HighLimit	RPD RefVal	%RPD	RPDLimit	Qual
Copper	0.3129	0.000520	0.1	0.2176	95.3	70	130	0.3256	3.97	20	
Lead	0.1110	0.000104	0.1	0.01433	96.6	70	130	0.1089	1.89	20	

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Neilson
RESEARCH
CORPORATION
Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax: (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: Spring Street Analytical
Address: 350 Spring Street
Klamath Falls OR 97601
Email: waterlab@gwestoffice.net
Phone: 541-882-6286 Fax: 541-882-9561
Collected By (Print): Andy Foster
Collected By (Sign): Andy Foster
Email Report Yes No
Fax Report Yes No

Section B
Required Project Information

Project Name:
Project Number:
Report To: Spring Street Analytical
Copy To:
P.O. #

Section C
Invoice Information

Attention:
Company Name: Spring Street Analytical
Address:
P.O. #

Section D
Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
Other _____
Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Lead / Copper	School Specials	Analysis Requested
11738	Shots Room #1	DW	6/24/16	7:03 AM	1		X	
16733	Shots Room #3	DW	6/24/16	7:05 AM	1		Y	
16714	Stearns Drinking Fountain	DW	6/24/16	7:12 AM	1		Y	
11741	Ferguson Room #25	DW	6/24/16	7:14 AM	1		X	
11722	Ferguson Room #15	DW	6/24/16	7:20 AM	1		X	
16715	Ferguson Room #16	DW	6/24/16	7:33 AM	1		X	
16719	Stearns Room #3	DW	6/24/16	7:30 AM	1		X	
11740	Stearns Room #4	DW	6/24/16	7:32 AM	1		X	
11701	Nitzem G.O.F. by Office	DW	6/24/16	7:35 AM	1		X	

Section F
Retainquish/Receive

Retainquish/Receive	Sign	Date	Time
Retainquished By:			
Retainquished By:			
Received By:			
Received By:			
Received By:			
Received By Laboratory:	<u>Denise Deal</u>	<u>6/29/16</u>	<u>13:40</u>

Section G
Lab Use Only

Temp: 13.8
4°C - 12°C: Yes No
Received on ice: Yes No
Number of Bottles Received: 110
pH Checked: NA
COC Seals Intact: Yes No
Field Blank Included: Yes No

Payment: Invoice Cash
Received Via: UPS FedEX Other
MISA/MC/Check # _____ Amount _____

